

Construction Works of MTRCL-WIL
Latest Audited Noise Monitoring Results

Identification No.	Monitoring Location	Work Site	Noise Level (in dB(A)) (Leq 30)	Within EM&A Limit Level
CN1	Chee Sing Kok Social Centre of The Humanity Love	Victoria Road Temporary Underground Magazine	works completed	
CN2	Hong Kong Academy	Ex-police Quarter, Kennedy Town	68.7 (17.2.2011; 9:30 am)	✓
CN3	Lui Ming Choi Primary School	Sai See Street Work Site	66.9 (9.2.2011; 3:00 pm)	✓
CN4	Luen Tak Apartments	Forbes Street	68.4 (9.2.2011; 4:00 pm)	✓
CN5	Western Court (Block 1)	Whitty Street Public Toilet	works not commenced yet	
CN6	Yick Fung Garden (Block A)	Sing Sai Road Reprovisioning of Swimming Pool	72.6 (17.2.2011; 4:05 pm)	✓
CN7A	Bowie Court	HKU Haking Wong Bldg	72.6 (17.2.2011; 3:15 pm)	✓
CN8	St. Paul's College Primary School	HKU Yam Pak Bldg	70.0 (17.2.2011; 2:15 pm)	✓
CN9	Hill Court	Hill Road	67.1 (17.2.2011; 1:20 pm)	✓
CN11A	Yick Fung Garden (Block B)	Belcher's Street near the Westwood Rest Garden	72.6 (8.2.2011; 11:22 am)	✓
CN12	Wah Po Building	Western District PCWA	67.5 (17.2.2011; 10:30 am)	✓
CN13	No. 18-20 Eastern Street	Sao Woo Lane	73.3 (16.2.2011; 1:30 pm)	✓
CN14	Bon-Point	David Trench Rehabilitation Centre	works not commenced yet	
CN15	Ivy Tower	Centre Street Cooked Food Centre	72.2 (7.2.2011; 10:22 am)	✓
CN16	No. 9-11 Ki Ling Lane	Ki Ling Lane	74.3 (15.2.2011; 3:57 pm)	✓
CN17	No. 1 Third Street	King George V Memorial Park	73.5 (16.2.2011; 2:10 pm)	✓
CN18	Princeton Tower	Des Voeux Road West	73.1 (15.2.2011; 9:05 am)	✓
CN20	Ka On Building	New Market Street	72.8 (17.2.2011; 3:45 pm)	✓
CN21	The Merton (Block 2)	Sai See Street	71.3 (9.2.2011; 4:50 pm)	✓