

Annex 2

Month	2012 Local Maximum Demand(MW)	
	HKE	CLP
1	1,647	4,433
2	1,740	4,617
3	1,836	4,835
4	2,157	5,641
5	2,324	6,214
6	2,383	6,472
7	2,432	6,598
8	2,494	6,769
9	2,396	6,441
10	2,045	5,476
11	1,933	5,116
12	1,706	4,635

Hour	2012 Local Peak Day Load Curve(MW)	
	HKE	CLP
01:00	1,404	5,270
02:00	1,289	4,774
03:00	1,231	4,419
04:00	1,201	4,220
05:00	1,182	4,106
06:00	1,223	4,157
07:00	1,454	4,498
08:00	1,834	5,061
09:00	2,159	5,701
10:00	2,303	6,188
11:00	2,375	6,422
12:00	2,419	6,558
13:00	2,448	6,549
14:00	2,494	6,507
15:00	2,461	6,459
16:00	2,405	6,460
17:00	2,396	6,459
18:00	2,347	6,451
19:00	2,275	6,608
20:00	2,167	6,769
21:00	2,027	6,746
22:00	1,919	6,655
23:00	1,785	6,513
24:00	1,617	6,055