

**Flexible and pragmatic measures or alternatives
approved for buildings that have fully complied with FS Directions**

| Flexible and pragmatic measure/alternative | Number of buildings involved* |
|---|--------------------------------------|
| For buildings not exceeding six storeys (about 20 metres high), hose reel systems, but not fire hydrants, were required (the capacity of fire service water tanks required was significantly reduced to not less than 2 000 litres) | 21 |
| Exempted from increasing the capacity of the existing fire service water tanks of the buildings | 4 |
| Exempted from installing hose reel systems and water tanks, and only manual fire alarm systems and fire extinguishers were required | 3 |
| Installation of improvised automatic sprinkler systems (with a direct town mains connection or a water tank shared with fire hydrant/hose reel systems) | 7 |

* As one of the buildings adopted two measures/alternatives, the total number of buildings involved exceeds that of buildings which have fully complied with the FS Directions.