

Statistics of Water Sample Tests of Fresh Water Cooling Towers in 2014淡水冷卻塔水樣本檢測統計數字-2014 年

## (a) Routine surveillance inspections by EMSD

## 機電署例行監察巡查

	Total (from Jan up to Mar 2014) 總數 (2014 年 1 月至 3 月)
No. of water samples from fresh water cooling towers tested by EMSD (No. of buildings involved) 機電工程署檢測的淡水冷卻塔水樣本數目 (涉及的建築物數量)	280 (234)
No. of water samples with LBC at or above the upper threshold (i.e. 1,000 cfu/ml) with nuisance notices issued 退伍軍人病菌數量等於或超過其上限值(即每毫升 1 000 菌落)及已發出「妨擾事故通知」的水樣本數目	0
No. of water samples detected with LBC between 10 and 1000 cfu/ml 退伍軍人病菌數量介乎每毫升 10 菌落至每毫升 1 000 菌落之間的水樣本數目	57

## (b) Inspections other than routine surveillance inspection

## 例行監察巡查以外的其他檢查

	Total (from Jan up to Mar 2014) 總數 (2014 年 1 月至 3 月)
No. of water samples with LBC at or above the upper threshold (i.e. 1,000 cfu/ml) with nuisance notices issued 退伍軍人病菌數量等於或超過其上限值(即每毫升 1 000 菌落)及已發出「妨擾事故通知」的水樣本數目	0

Electrical &amp; Mechanical Services Department

機電工程署

(Updated on 1 April 2014)

(2014 年 4 月 1 日更新)