

Statistics of Water Sample Tests of Fresh Water Cooling Towers in 2015
淡水冷卻塔水樣本檢測統計數字-2015 年

(a) Routine surveillance inspections by EMSD
機電署例行監察巡查

| | Total (from Jan up to May 2015) 總數 (2015 年 1 月至 5 月) |
|--|---|
| No. of water samples from fresh water cooling towers tested by EMSD (No. of buildings involved) 機電工程署檢測的淡水冷卻塔水樣本數目 (涉及的建築物數量) | 377 (315) |
| No. of water samples with LBC at or above the upper threshold (i.e. 1,000 cfu/ml) with nuisance notices issued 退伍軍人病菌數量等於或超過其上限值(即每毫升 1 000 菌落)及已發出「妨擾事故通知」的水樣本數目 | 4 |
| No. of water samples detected with LBC between 10 and 1000 cfu/ml 退伍軍人病菌數量介乎每毫升 10 菌落至每毫升 1 000 菌落之間的水樣本數目 | 57 |

(b) Inspections other than routine surveillance inspections

(To assist epidemiological investigation of the Centre for Health Protection to collect water samples for testing)

例行監察巡查以外的其他檢查 (協助衛生防護中心流行病學調查抽取水樣本進行化驗)

| | Total (from Jan up to May 2015) 總數 (2015年1月至5月) |
|---|--|
| No. of water samples from fresh water cooling towers tested. (No. of buildings involved) 檢測的淡水冷卻塔水樣本數目 (涉及的建築物數量) | 2 (2) |
| No. of water samples with LBC at or above the upper threshold (i.e. 1,000 cfu/ml) with nuisance notices issued 退伍軍人病菌數量等於或超過其上限值(即每毫升 1 000 菌落) 及已發出「妨擾事故通知」的水樣本數目 | 0 |
| No. of water samples detected with LBC between 10 and 1000 cfu/ml 退伍軍人病菌數量介乎每毫升 10 菌落至每毫升 1 000 菌落之 間的水樣本數目 | 1 |

Electrical & Mechanical Services Department

機電工程署

(Updated on 5 June 2015)

(2015年6月5日更新)