

**Test results of water samples taken from public rental housing estates completed before 2005**

The Housing Department (HD) and the Water Supplies Department (WSD) are conducting a representative screening for public rental housing (PRH) estates completed before 2005 in which the fresh water supply systems were installed by the Hong Kong Housing Authority, to determine whether the lead content in drinking water exceeds the World Health Organisation (WHO)'s provisional guideline value of not more than 10 micrograms per litre. In general, HD and WSD are taking water samples for testing by batches in accordance with the completion year of the PRH estates, starting with newly completed estates and working back to the older ones. Once a batch of water sample tests is completed, HD will immediately announce the testing results.

**(Results announced for 54 PRH estates involving 1195 water samples up to 22 October 2015)**

**Lead content in water samples complying with WHO's provisional guideline value**

Tsui Ping (South) Estate	Lee On Estate	Butterfly Estate	Choi Fai Estate	Sai Wan Estate	Choi Yuen Estate	Tin Yan Estate	Tsz Lok Estate	Oi Tung Estate
Kwai Shing (East) Estate	Kin Ming Estate	Tin Yuet Estate	Po Tat Estate	Lei Yue Mun Estate	Tin Heng Estate	Tin Chak Estate	Sau Mau Ping Estate	Fu Tai Estate
Wang Tau Hom Estate	Ap Lei Chau Estate	Lei Muk Shue (I) Estate	Chun Shek Estate	Pak Tin Estate	Ka Fuk Estate	On Yam Estate	Sheung Tak Estate	Cheung Hang Estate
Yiu Tung Estate	Tsz Man Estate	Wah Sum Estate	Shek Lei (I) Estate	Tin Wan Estate	Ko Yee Estate	Wan Hon Estate	Sheung Lok Estate	Tsz Ching Estate
Kwai Fong Estate	Chung On Estate	Ho Man Tin Estate	Ko Cheung Court (the PRH portion)	Upper Wong Tai Sin Estate	*Tin Shui (II) Estate	*Tai Wo Hau Estate	*Cheung Hong Estate	*Hau Tak Estate
*Shun Tin Estate	*Wan Tsui Estate	*Sun Chui Estate	*Mei Lam Estate	*Kwong Fuk Estate	*Shek Kip Mei Estate	*Lung Hang Estate	*Lei Muk Shue (II) Estate	*Hing Wah (I) Estate

*\*13 estates announced on 22 October*