

Concentrations ($\mu\text{g}/\text{m}^3$) of SO₂ and NO₂ and status of compliance with relevant Air Quality Objectives (AQOs) at Lung Kwu Tan Village monitoring station of CLP Power Hong Kong Limited in 2019

	Short-term AQOs			Long-term (annual) AQOs ^{Note 2}
Pollutant	Sulphur dioxide (SO ₂)		Nitrogen dioxide (NO ₂)	
Average time	10-minute	24-hour	1-hour	1-year
Concentration limit under AQOs	500	125	200	40
Number of exceedances allowed	3	3	18	Not applicable
Year	Short-term concentrations ^{Note 1} , number of exceedances (in brackets) and compliance with the standard? (Yes/No)			Annual average concentrations and compliance with the standard ^{Note 2?} (Yes/No)
2019	44(0) / Yes	15(0) / Yes	133(0) / Yes	27 / Yes

note 1: The short-term SO₂ concentrations are the fourth highest levels and the short-term NO₂ concentration is the nineteenth highest level.

note 2: There is no long-term AQO for SO₂.