

Substandard working platform
In contravention of Regulation 38B of the
Construction Sites (Safety) Regulations



**No guard-rails, toe-boards,
outriggers or access and
egress are provided on the
working platform**