

Statistics of Water Sample Tests of Fresh Water Cooling Towers in 2022

淡水冷卻塔水樣本檢測統計數字-2022 年

(a) Routine surveillance inspections by EMSD

機電署例行監察巡查

| | Total (From Jan up to Oct 2022) 總數 (2022 年 1 月至 10 月) |
|--|--|
| No. of water samples from fresh water cooling towers tested by EMSD (No. of buildings involved) 機電工程署檢測的淡水冷卻塔水樣本數目 (涉及的建築物數量) | 671 (436) |
| No. of water samples with total legionella count at or above the upper threshold (i.e. 1 000 cfu/ml) with nuisance notices issued 退伍軍人桿菌總濃度等於或超過其上限值(即每毫升 1 000 菌落)及已發出「妨擾事故通知」的水樣本數目 | 21 |
| No. of water samples detected with total legionella count between 10 and 1 000 cfu/ml 退伍軍人桿菌總濃度介乎每毫升 10 菌落至每毫升 1 000 菌落之間的水樣本數目 | 157 |

- (b) Inspections other than routine surveillance inspections
 (To assist epidemiological investigation of the Centre for Health Protection to collect water samples for testing)
 例行監察巡查以外的其他檢查 (協助衛生防護中心流行病學調查抽取水樣本進行化驗)

| | Total (From Jan up to Oct 2022) 總數 (2022年1月至10月) |
|--|---|
| No. of water samples from fresh water cooling towers tested. (No. of buildings involved) 檢測的淡水冷卻塔水樣本數目 (涉及的建築物數量) | 5 (4) |
| No. of water samples with total legionella count at or above the upper threshold (i.e. 1 000 cfu/ml) with nuisance notices issued 退伍軍人桿菌總濃度等於或超過其上限值(即每毫升 1 000 菌落)及已發出「妨擾事故通知」的水樣本數目 | 0 |
| No. of water samples detected with total legionella count between 10 and 1 000 cfu/ml 退伍軍人桿菌總濃度介乎每毫升 10 菌落至每毫升 1 000 菌落之間的水樣本數目 | 0 |

Electrical & Mechanical Services Department
 機電工程署
 (Updated on 7 November 2022)
 (2022年11月7日更新)