

Status of “Main Burst Hotspots” (Note 1)

District	As at end-2021		As at end-2022		As at November, 30, 2023	
	No. of hot-spots (Note 2)	No. of completed improvement works (Note 3)	No. of hot-spots (Note 2)	No. of completed improvement works (Note 3)	No. of hot-spots (Note 2)	No. of completed improvement works (Note 3)
Central & Western	1	2	2	0	2	0
Eastern	2	0	2	0	2	0
Islands	0	0	0	0	0	0
Southern	0	0	0	0	0	0
Wan Chai	2	1	1	1	0	1
Kowloon City	2	1	0	2	0	0
Kwun Tong	0	0	0	0	0	0
Sham Shui Po	0	0	0	0	0	0
Wong Tai Sin	0	0	0	0	0	0
Yau Tsim Mong	4	1	0	4	0	0
North	0	0	0	0	0	0
Sai Kung	0	2	0	0	0	0
Sha Tin	0	0	0	0	0	0
Tai Po	0	0	0	0	0	0
Kwai Tsing	2	2	1	1	0	1
Tsuen Wan	0	0	2	0	2	0
Tuen Mun	0	1	1	0	2	0
Yuen Long	1	0	0	1	0	0
Total	14	10	9	9	8	2

Note 1: The “main burst hotspot” is designated as a location at which more than one burst (excluding of damage or suspected damage caused by others) of water main (with diameter of 150 millimetres or above) occurs within a 400-metre long road section in two years.

Note 2: The figure covers “main burst hotspots” for which works are being planned or under construction, as well as new hotspots identified within the year.

Note 3: The figure refers to the water mains improvement works completed in the year. Improvement works for hotspots takes some four years in average from planning and design to construction completion. As such, the number of improvement works completed in the year does not correlate to the number of hotspots in the year.