

**Power Outage Incidents of the Two Power Companies from July 2021 till Now****CLP Power Hong Kong Limited (CLP)**

	<b>Date</b>	<b>Affected Area</b>	<b>Duration of Power Supply Interruption</b>	<b>Number of Affected Electricity Customers</b>	<b>Cause of Incident (External Factors or Internal Factors)</b>
<b>2021</b>					
1	16 August	Wing Ning Wai, Fanling	Around 182 minutes	1	Internal factor: Equipment fault
2	8 October	Ta Kwu Ling	Around 30 minutes	1	Internal factor: Equipment fault
3	10 December	Kam Tin	Around 59 minutes	4	Internal factor: Equipment fault
4	19 December	Ngau Tau Kok	Around 3 minutes	2 039	Internal factor: Equipment fault
<b>2022</b>					
1	15 February	Sheung Shui	Around 119 minutes	1	Internal factor: Equipment fault
2	27 February	Hong Kong–Zhuhai–Macao Bridge	Around 3 minutes	58	Internal factor: Equipment fault
3	25 March	Chuk Yuen Estate	Around 21 - 125 minutes	2 181	External factor: Water leakage in the customer's building
4	30 May	Au Tau Water Treatment Works	Around 111 minutes	13	Internal factor: Equipment fault
5	21 June	Tuen Mun, Yuen Long and Tin Shui Wai	Around 7 – 13 hours	Around 175 000	Internal factor: Equipment fault
6	23 June	Yuen Long	Around 7 - 29 minutes	Around 13 400	Internal factor: Equipment fault
7	13 July	Tsuen Wan	Around 90 minutes	17	External factor: Third party interference
8	17 July	Yuen Long	Around 110 minutes	184	Internal factor: Equipment fault
9	20 July	Yuen Long	Around 190 minutes	65	Internal factor: Equipment fault

10	27 August	Yuen Long	Around 160 minutes	138	External factor: Third party interference
11	29 August	Kwun Tong	Around 3 minutes	Around 19 800	Internal factor: Equipment fault
<b>2023</b>					
1	15 April	Kowloon East	Around 3 - 45 minutes	Around 14 300	Internal factor: Equipment fault
2	20 May	Discovery Bay	Around 3 - 217 minutes	1 523	External factor: Third party interference
3	31 July	World-Wide Gardens	Around 2 - 195 minutes	1 790	External factor: Third party interference
4	2 September	Kowloon and New Territories	Around 2 - 38 hours	Around 6 400	External factor: Adverse weather
5	7 September	Classical Gardens	Around 132 minutes	497	External factor: Adverse weather
6	31 October	Cheung Chau	Around 20 minutes	14	External factor: Third party interference
7	30 December	Cheung Tung Road, Tung Chung	Around 1 - 6 hours	26	External factor: Third party interference
<b>2024</b>					
1	7 January	On Mei House, Tsing Yi	Around 86 minutes	388	Internal factor: Equipment fault
2	19 March	Yuen Long	Around 109 minutes	68	Internal factor: Human factor
3	10 April	Sheung Shui Wai	Around 30 - 168 minutes	2 912	External factor: Third party interference
4	12 June	Wong Tai Sin	Around 4 hours	2 256	Cause of incident under review and to be confirmed by Electrical and Mechanical Services Department

Remarks: CLP does not keep the number of manpower dispatched for emergency repair for each incident.

The Hongkong Electric Company Limited (HEC)

	<b>Date</b>	<b>Affected Area</b>	<b>Duration of Power Interruption</b>	<b>Affected Electrical Customers</b>	<b>Cause of Incident (External Factors or Internal Factors)</b>
<b>2022</b>					
1	12 July	Chai Wan	Around 6 minutes	Around 8 380	Internal factor: Human factor
<b>2023</b>					
1	19 April	Hong Kong area	Around 33 - 48 minutes	Around 44 000	Internal factor: Human factor
2	16 July	Connaught Road Central	Around 23 hours	55	External factor: Water leakage in the customer's building
3	7 September	Hong Kong area (affected by black rainstorm)	Around 1 - 23 hours	3 186	External factor: Adverse weather
<b>2024</b>					
1	5 February	Tai Yuen Street, Wan Chai	Around 3.5 hours	53	External factor: Third party interference

Remarks:

- (1) HEC does not keep the number of manpower dispatched for emergency repair for each incident.
- (2) According to the record of incidents under reporting mechanism, there was not any significant power outage incident in 2021 for HEC.