

Statistics of Water Sample Tests of Fresh Water Cooling Towers in 2024

淡水冷卻塔水樣本檢測統計數字-2024 年

(a) Routine surveillance inspections by EMSD

機電署例行監察巡查

	Total ( From Jan up to Sep 2024 ) 總數 (2024 年 1 月至 9 月)
No. of water samples from fresh water cooling towers tested by EMSD (No. of buildings involved)  機電工程署檢測的淡水冷卻塔水樣本數目 ( 涉及的建築物數量 )	639  (382)
No. of water samples with total legionella count at or above the upper threshold (i.e. 1 000 cfu/ml) with nuisance notices issued  退伍軍人桿菌總濃度等於或超過其上限值(即每毫升 1 000 菌落) 及已發出「妨擾事故通知」的水樣本數目	17
No. of water samples detected with total legionella count between 10 and 1 000 cfu/ml  退伍軍人桿菌總濃度介乎每毫升 10 菌落至每毫升 1 000 菌落之間的水樣本數目	124

- (b) Inspections other than routine surveillance inspections  
 (To assist epidemiological investigation of the Centre for Health Protection to collect water samples for testing)  
 例行監察巡查以外的其他檢查 (協助衛生防護中心流行病學調查抽取水樣本進行化驗)

	Total ( From Jan up to Sep 2024 ) 總數 ( 2024 年 1 月至 9 月 )
No. of water samples from fresh water cooling towers tested. (No. of buildings involved) 檢測的淡水冷卻塔水樣本數目 ( 涉及的建築物數量 )	10 (5)
No. of water samples with total legionella count at or above the upper threshold (i.e. 1 000 cfu/ml) with nuisance notices issued 退伍軍人桿菌總濃度等於或超過其上限值(即每毫升 1 000 菌落) 及已發出「妨擾事故通知」的水樣本數目	0
No. of water samples detected with total legionella count between 10 and 1 000 cfu/ml 退伍軍人桿菌總濃度介乎每毫升 10 菌落至每毫升 1 000 菌落之間的水樣本數目	3

Electrical & Mechanical Services Department  
 機電工程署  
 (Updated on 8 October 2024)  
 ( 2024 年 10 月 8 日更新 )