

**Main burst incidents in Kowloon West
between January and October 2024**

	Date	Location	Pipe material/Age	Cause of incident
1	September 29	Lai Chi Kok Road near Cheung Sha Wan Police Station	Cast iron fresh water pipe/ Approx. 50 years	As the incident has caused road subsidence, the Development Bureau is reviewing the investigation report submitted by the Water Supplies Department and will give an account on the cause of the incident in a timely manner.
2	September 17	Tonkin Street near Lei Cheng Uk Playground	Cast iron salt water pipe/ Approx. 54 years	Pipe aging
3	September 3	Man Sing Street near Man Wui Street	Ductile iron salt water pipe/ Approx. 30 years	Corrosion of pipe fitting
4	August 22	Sham Mong Road near Tonkin Street West	Mild steel salt water pipe/ Approx. 29 years	Corrosion of pipe fitting
5	January 16	Tai Kok Tsui Road near Pok Man Street	Ductile iron salt water pipe/ Approx. 25 years	Corrosion of pipe fitting